

CHAPTER 21
Fire Prevention
(Rep. & recr. #48-83) (Am. #10-99)

21.05 Flammable and Combustible Liquids

- (1) (Am. #4-17) The provisions in this section are in addition to those in ATCP 93 as adopted above.
- (2) Waste oil storage that is not in an approved tank system is limited to three 55 gallon DOT drums which are free of dents and corrosion. Such drums may not be stored outside.
- (3) All gasoline stored within buildings shall be stored in approved safety cans.

WAUKESHA MUNICIPAL CODE 06/26/17